



RIVIERA BEACH COMMUNITY REDEVELOPMENT AGENCY

**ITB NO. 2018-01**  
**ADDENDUM No. 004**  
**Posted June 19, 2018**

**UPDATE**

1. **Question:** SHEETS AD 1.0, AD 1.1, & AD 1.2, DEMOLITION KEY NOTE D1 CALLS FOR CUTTING WALL 10 ABOVE PAVERS, PLEASE CLARIFY.

**Answer:** Refer sections and details of the drawings. The intent is saw cut the wall so that when the cast concrete cap is installed the height of the wall will be 12" above the pavers.

2. **Question:** BID COST SHEET SHOWS 3 OPTIONS, DRAWINGS SHOW 2 ALTERNATES, PLEASE CLARIFY

**Answer:** Please reference the bid document attachments for all three options which consist of a new wave rail, aluminum, and cable.

3. **Question:** SHEET AD 1.0 SEEMS TO SHOW CONCRETE SLAB RATHER THAN PAVERS. Is this true?

**Answer:** The pavers were left out for the sake of clarity. Concrete pavers are the finish material.

4. **Question:** SHEET AD 1.0 SITE DEMOLITION LEGEND SHOWS 2" CONCRETE CAP TO BE REPLACED & REUSED CONCRETE CAP, PLEASE CLARIFY. DEMOLITION KEY NOTE D-4 SAYS TO REINSTALL

**Answer:** The intent of the note is to direct the demolition contractor to saw cut the wall 10" above the pavers. But before the removing the wall, remove the case stone cap and store it until it can be reinstalled. A large portion of the concrete caps have guard rails with supports that required those concrete cap to be cored so that the guard rails could be installed. These concrete cap will have to be replaced with new ones.

**Any amendments to this ITB will be posted on our website at <http://www.rbcra.com> . It is the vendor's sole responsibility to routinely check this website for any amendments that may have been issued prior to the deadline for receipt of ITB submittal packets.**

Submissions will be opened and evaluated in the Riviera Beach CRA conference room at 2001 Broadway Suite 300, Riviera Beach, FL, 3:30 PM, July 6, 2018, or as soon thereafter as is practical by the evaluation committee.

This notice does not bind RBCRA to pursue further steps with any interested parties. Accordingly, RBCRA is not liable for any costs incurred in connection with the submittal of materials in response to this request.

The CRA reserves the right to reject any and/or all submissions and waive technicalities and/or any irregularities therein. The CRA further reserves the right to award a contract to that qualified proposer whose proposal best serves the interests of the CRA in the sole discretion of the CRA.

All responses must be complete upon initial submission. Faxed responses will **not** be accepted. Electronic versions will **not** be accepted. Submissions will be time and date stamped.

Andre' Lewis  
(561) 844-3408  
Email: [alewis@rbcra.com](mailto:alewis@rbcra.com)